

Memo No:- 119

Date:- 29/02/2024

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : SNP/04197/2/2024 / Private	Sample Details	Date & Time
Sender : C.C.A.S. Jain Senior Secondary School28576	Collected By	C.C.A.S. Jain ...
Location : , G.T. ROAD GANAUR	Collection Date	26/02/2024 at 13:15
Sample Description : Drinking Water	Received at lab	26/02/2024 at 13:21
Latitude / Longitude : 77.040017 / 29.144056	Analysis Start Date	26/02/2024
	Analysis End Date	27/02/2024
	Sample Quantity	2 Ltrs

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	103	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
2	Total Hardness as CaCo3	76	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
3	Calcium as Ca	14.43	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	9.62	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
5	Chloride as Cl	14.99	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
6	pH @ 25°C	7.32	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
7	Total Alkalinity	84	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
8	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
9	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
10	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
11	Turbidity	0.54	1 NTU	5 NTU	APHA 24th Edition -2130 B
12	Iron as Fe	0.00	1.0 mg/lit.	1.0 mg/lit.	USEPA
13	Sulphate as So4	6	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E
14	Fluoride as F	0.11	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
15	Nitrate as No3	0.0	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D


Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED SONIPAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



Sample analyzed by :


Principal
CCAS Jain Sr. Sec. School
Ganaur

DEEPIKA ,CHEMIST
DISTRICT WATER TESTING LABORATORYSONIPAT
email:-chemist.sonepat@phedharyana.gov.in


President
CCAS Jain Sr. Sec. School
Ganaur (Sonepat)